



OFFICE OF COUNTY MAYOR TIM BURCHETT

Department of Engineering & Public Works • Stormwater Management
205 West Baxter Avenue, Knoxville, TN 37917

December 23, 2010

USPS Tracking # 7009 1410 0000 9455 2874

Charles McMillian
4715 McCampbell Dr
Knoxville, TN 37918

Notice of Violation

Re: Violation of Knox County's Ordinance for Stormwater Management, O-07-12-101
Cell Tower on McCampbell Dr.

Dear Mr. McMillian,

On December 20, 2010 Steve Elliott and Jamey Casteel conducted an inspection of the above referenced location to determine compliance with Knox County's Ordinance for Stormwater Management, O-07-12-101 (henceforth known as Knox County's Stormwater Ordinance). During the site investigation the following violations were observed:

4.1: Failure to install erosion and sediment controls before earth-moving operations begin.

- Sections 7.1 and 7.2(b) of Knox County's Stormwater Ordinance specify that EPSC control measures shall be properly installed and maintained in accordance with TDEC's Erosion & Sediment Control Handbook for all land disturbing activities. An inspection of your site on December 20, 2010 found your site to be deficient in this area. Grading has taken place on your property and no erosion controls were in place. You are required to install any necessary controls to prevent sediment from escaping your construction site. You are required to rectify the problem immediately in order to avoid further penalties.



The red line indicates where erosion controls need to be installed.



OFFICE OF COUNTY MAYOR TIM BURCHETT

Department of Engineering & Public Works • Stormwater Management
205 West Baxter Avenue, Knoxville, TN 37917

Given the facts presented, Knox County is issuing you this Notice of Violation to make you aware of deficiencies at your site in the above listed areas. Please be advised that further penalties may result for each additional day of noncompliance in reference to each of the violations listed above. Under the amended section of Knox County's Stormwater Ordinance, Section 16, violators can be fined up to \$5,000 per day per violation.

I look forward to a timely resolution to this situation. If you have questions regarding this letter, please feel free to contact me at 865-215-5840. You may also contact Knox County Inspector, Steve Elliott at 865-215-5869 or steve.elliott@knoxcounty.org.

Sincerely,

Christopher Granju, P.E.

Stormwater Management Coordinator

Knox County